



沧州会友线缆股份有限公司



天下朋友



沧州会友线缆股份有限公司



CERTIFICATE NUMBER: CE-C-0512-08-39-02-A

CERTIFICATE OF CONFORMITY

NAME AND ADDRESS OF THE MANUFACTURER: CANGZHOU HUIYOU CABLE STOCK CO., LTD
LIZHANGGE VILLAGE, ZUNZUZHANG TOWN, HEJIAN CITY,
HEBEI (SOUTH OF SHIBEI ROAD)

PRODUCT DESCRIPTION: 6-35KV XLPE insulated PVC sheathed power cable
TYPE AND MODEL: Types and specification of the above cable approved are shown on the
SERIES NUMBER: page 2

APPLICABLE STANDARDS: IEC 60502-2:2005

APPLICABLE EC DIRECTIVES:

TECHNICAL FILE (TCF) REFERENCE NUMBER: TF-CZHY-0512-08



Based on the voluntary assessment of the product sample and technical file, we certify that the above-mentioned product meets the requirements of the EC directives.

The manufacturer has the responsibility for ensuring that all serial manufacture of the product is in compliance with the specification of the sample submitted for assessment and detailed in the technical file.

CCQS UK Ltd.
10 Nursery Close, Headington
Oxford, OX3 7AG, UK
Tel: +0044(0) 1865 767927
Fax: +0044(0) 1865 427004
Email: yan.gao@ccqsuk.com


APPROVED / SIGNED BY PRESIDENT
CCQS UK LTD

DATE OF ISSUE: 18th Dec. 2008





沧州会友线缆股份有限公司



CERTIFICATE NUMBER: CE-C-0512-08-39-02-A

This supplement is only valid in conjunction with page 1 of the certificate No. CE-C-0512-08-39-02-A

Rated voltage 6/6kV:

YJV(YJV22), $1 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 35 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 35 \sim 300 \text{mm}^2$.

Rated voltage 8.7/10kV:

YJV(YJV22), $1 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 35 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 35 \sim 300 \text{mm}^2$.

Rated voltage 8.7/15kV:

YJV(YJV22), $1 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 35 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 35 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 35 \sim 300 \text{mm}^2$.

Rated voltage 12/20kV:

YJV(YJV22), $1 \times 25 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 35 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 35 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 35 \sim 300 \text{mm}^2$.

Rated voltage 21/35 kV:

YJV(YJV22), $1 \times 50 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 50 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 50 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 50 \sim 300 \text{mm}^2$.

Rated voltage 26/35kV:

YJV(YJV22), $1 \times 50 \sim 300 \text{mm}^2$; YJLV(YJLV22), $1 \times 50 \sim 300 \text{mm}^2$

YJV(YJV22), $3 \times 50 \sim 300 \text{mm}^2$; YJLV(YJLV22), $3 \times 50 \sim 300 \text{mm}^2$.





沧州会友线缆股份有限公司



CERTIFICATE NUMBER: CE-C-0512-08-39-01-1A

CERTIFICATE OF CONFORMITY

NAME AND ADDRESS OF THE MANUFACTURER: CANGZHOU HUIYOU CABLE STOCK CO., LTD
LIZHANGGE VILLAGE, ZUNZUZHANG TOWN, HEJIAN CITY,
HEBEI (SOUTH OF SHIBEI ROAD)

PRODUCT DESCRIPTION: 0.6/1kV XLPE insulated PVC sheathed power cable;
TYPE AND MODEL: Types and specification of the above cable approved are shown on the
SERIES NUMBER: page 2.

APPLICABLE STANDARDS: IEC 60502-1:2003

APPLICABLE EC DIRECTIVES: 2006/95/EC LOW VOLTAGE DIRECTIVE

TECHNICAL FILE (TCF) REFERENCE NUMBER: TF-CZHY-0512-08



Based on the voluntary assessment of the product sample and technical file, we certify that the above-mentioned product meets the requirements of the EC directives.

The manufacturer has the responsibility for ensuring that all serial manufacture of the product is in compliance with the specification of the sample submitted for assessment and detailed in the technical file.

CCQS UK Ltd.
10 Nursery Close, Headington
Oxford, OX3 7AG, UK
Tel: +0044(0) 1865 767927
Fax: +0044(0) 1865 427004
Email: yan.gao@ccqsuk.com


APPROVED / SIGNED BY PRESIDENT
CCQS UK LTD

DATE OF ISSUE: 18th Dec. 2008





沧州会友线缆股份有限公司



CERTIFICATE NUMBER: CE-C-0512-08-39-01-1A

This supplement is only valid in conjunction with page 1 of the certificate No. CE-C-0512-08-39-01-1A

Rated voltage: 0.6/1kV

YJV(YJV22), 1×1.5~300mm²; YJLV(YJLV22), 1×2.5~300mm²;

YJV(YJV22), 2×1.5~185mm²; YJLV(YJLV22), 2×2.5~300mm²;

YJV(YJV22), 3×1.5~300mm²; YJLV(YJLV22), 3×2.5~300mm²;

YJV(YJV22), (3+1)×4~300mm²; YJLV(YJLV22), (3+1)×4~300mm²;

YJV(YJV22), 4×1.5~300mm²; YJLV(YJLV22), 4×1.5~300mm²;

YJV(YJV22), (3+2)×6~300mm²; YJLV(YJLV22), (4+1)×6~300mm²;

YJV(YJV22), 5×1.5~300mm²; YJLV(YJLV22), 5×2.5~300mm²;



CE



沧州会友线缆股份有限公司

TUV((德国技术监督协会) 光伏电缆认证证书

TÜV Rheinland LGA Products GmbH
(TRLP)
D-90431 Nürnberg
Germany



Certificate

No. 006-09-4133-0325

Regarding the inspection of
manufacturing and operating facilities according to the General Agreement
with the Certification Body of TRLP
the Certificate Holder

CANGZHOU HUIYOU CABLE STOCK CO., LTD.
LIZHUANGGE VILLAGE, ZUNZUZHANG TOWN,
HEJIAN CITY, CANGZHOU, HEBEI
P.R. China

has successfully demonstrated that an internal quality control
of those products approved by TÜV Rheinland is being carried out
and produced at the manufacturing facility

CANGZHOU HUIYOU CABLE STOCK CO., LTD.
LIZHUANGGE VILLAGE, ZUNZUZHANG TOWN,
HEJIAN CITY, CANGZHOU, HEBEI
P.R. China

An inspection of the manufacturer's quality control procedures and
internal records was conducted by a TÜV Rheinland appointed inspector on

19 March 2019

This certificate is valid until the next scheduled inspection
or up to 12 months, at the discretion of TÜV Rheinland.


Report-No. 50078247 003





沧州会友线缆股份有限公司

TÜV Rheinland (China) Ltd.
Member of TÜV Rheinland Group



CANGZHOU HUIYOU CABLE STOCK CO.,LTD.

Date : 1-Apr-19
Order No. : 190101276
Factory No. : 086-09-4133
Customer No. : 60036300

Mr. Qian Hanjie

LIZHUANGGE VILLAGE, ZUNZUZHUANG
TOWN, HEJIAN CITY, CANGZHOU, HEBEI
P.R. China

Factory-Inspection Certificate

Dear Mr. Guo Zhenjie,

On 19 Mar. 2019 our expert Ms. Vivian Ren performed the regular audit inspection at your factory:

CANGZHOU HUIYOU CABLE STOCK CO.,LTD.
LIZHUANGGE VILLAGE, ZUNZUZHUANG TOWN,
HEJIAN CITY, CANGZHOU, HEBEI
P.R. China

The inspection result confirmed the quality assurance of this factory to comply with the relevant requirements.

Enclosed please find our Factory Inspection Certificate, which could be displayed in your respective factory.

Please contact our office for safety approval of your new products. We appreciate your kind support and would like to offer our assistance and continuous service in the future. Please apply for the next factory inspection in 2020

Yours sincerely,

TÜV Rheinland (China) Ltd.

Liu Bo

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

TÜV Rheinland (China) Ltd.
Unit 707, AVIC Bldg.,
No.10B, Central Road,
East 3rd Ring Road,
Chaoyang District, Beijing,
100022, P.R.China
www.chn.tuv.com

莱茵检测认证服务(中国)有限公司
北京市朝阳区东三环中路
乙10号艾维克大厦707室
邮编 100022
www.chn.tuv.com

Tel: 86 10 6566 6660
Fax: 86 10 6566 6667
Hotline: 400 883 1300
800 999 3668
GC Service mailbox: service-gc@tuv.com

电话: 86 10 6566 6660
传真: 86 10 6566 6667
热线: 400 883 1300
800 999 3668
大中华区服务邮箱: service-gc@tuv.com



沧州会友线缆股份有限公司

MS-0007374_en 50078246 002_QMA30.105.04SHG_7.1 Confirmation Letter for Modification.doc

Version: 2013-08-01

TÜV RHEINLAND (CHINA) LTD.



To : CANGZHOU HUIYOU CABLE STOCK CO., LTD.
Attn. : Mr. Qian
LIZHANGGE VILLAGE, ZUNUZHUANG
TOWN, HEJIAN CITY, CANGZHOU CITY,
HEBEI (SOUTH OF SHIBEI ROAD) P.R. China

Date : 15 November, 2021
Customer Number
2184020
Page 1 of 1

Ref.: Approval of alternative component

Product Name : Cables for Photovoltaic-Systems
Type Designation : PV1-F 1X1.5...35mm²
Certificate No. : T 50376254 01
Report No. : 50078246 002
Reference Number : 50078246 001
Appendix No. : 1.1

Dear Mr. Qian,

We herewith recognize the alternative components as mentioned below:

Material of Sheath:	Halogen free crosslinked polyolefin ZL 1214-H-3 Colour: red Hebei Zhonglian Cathaya New Material Co., Ltd.
----------------------------	--

For your certified products as requested in the quotation(190019780), dated 27.05.2020.

For our annual factory inspection please keep this copy at the respective production site.

Please contact our office for safety approval of your new products.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Yours sincerely,

TÜV RHEINLAND (CHINA) LTD.

Bo Liu
Technical Certifier

Created by: Beverley Mak

Approved by: Holger Kunz

Page 1 of 1