

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2013010301603873

Valid from: Jun.24,2024

Valid until: Oct.11,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Shanghai JingDa Electrical Co.,Ltd
Room 406, No. 1, Lane 300, Henan South Road, Huangpu District, Shanghai

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Shanghai JingDa Electrical Co.,Ltd
Room 406, No. 1, Lane 300, Henan South Road, Huangpu District, Shanghai

NAME AND LOCATION OF THE FACTORY Shanghai Jingda Electric Complete Set Co., Ltd. Chongming Branch
Building 2, No.116, Xiangchun Road, Shuxin Town, Chongming District, Shanghai

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Switchgear Assemblies
JDXF 主母线:InA=400A ~ 16A,Icw=4.5kA;Un=380V,Ui=660V;50Hz;IP30;户内型

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 7251.2-2023

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.16,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>